

مرفق رقم (1) شركة مصافي الجنوب (شركة عامة)

العدد : 458
التاريخ: 2025/8/18

هياة المواد
شعبة الشراء المباشر

م/ اعلان طلبية شراء (2025/507)

تعلن شركة مصافي الجنوب (شركة عامة) طلبات شراء كما في ادناه فعلى الراغبين بالتجهيز التقديم على الطلبات المعلنة سحب استمارة العروض وكذلك الشروط والمواصفات واي مرفقات اخرى وأملانها (سعر المفرد والمجموع رقما وكتابة مع تثبيت التاريخ وكذلك التوقيع والختم الحي على استمارة العروض وكذلك الشروط والمواصفات وكافة المرفقات) ويرفق مع العرض المستمكات البيانات ادناه:

1-نسخة حديثة مصورة من هوية غرفة التجارة بالنسبة للمكاتب.

2-نسخة مصورة من هوية تصنيف بالنسبة للشركات.

3-نسخة مصورة من هوية الأحوال المدنية أو البطاقة الوطنية. للمدير المفوض

4-نسخة مصورة من بطاقة السكن 5-شهادته تأسيس الشركة

6- تزويدنا بعنوان كامل ودقيق للمجهز او الشركة واقرب نقطه داله ورقم الهاتف ويلتزم مقدم العطاء بتثبيت عنوانه و إيميل فعال كتابه في ورقه مستقله طباعه ومختوم وتقدم تأييد سكن حديث يتضمن مكان

الشركة او المكتب.

7-تقديم هوية ضريبية نافذة المفعول عند تقديم العروض وكذلك عند صرف المستحقات

يتم وضع العروض والمستمكات والبيانات اعلاه في مغلف ويعنون الى شركة مصافي الجنوب / قسم العقود والمشتريات ويثبت عليه المعلومات التالية :-

أ- رقم الطلبية وتاريخها ب- موضوع الطلبية ج- تاريخ الغلق.

د- أسم الشركة المقدمة مع الختم على طرفي المغلف .

و- مراجعة مقر الشركة الكائن في الشعبة / استعلامات الشركة الخارجية لغرض تسليم العروض في الصناديق المخصصة علما اخر موعد لتسليم العروض قبل الساعة الثانية عشر ظهرا من يوم الغلق .

عملية فساد او احتيال او تواطى سوف تلغى الاستمارة المقدمة ويتم ايقاف التعامل مع تلك 8- في حالة قيام الشركات او المكاتب بأي المكاتب او الشركات ويتم اتخاذ كافة الاجراءات القانونية بحقهم .

9- في حالة مصادفة يوم الغلق عطلة رسمية وعدم وجود دوام لأي سبب كان يؤجل موعد الغلق الى اليوم الذي يليه .

10- يكون تواجد لجنة استلام العروض ايام (الاحد - والثلاثاء - والخميس) من كل اسبوع

11- اعتبار تاريخ التبليغ عن طريق الايميل بداية فتره التجهيز على الإحالة

12- يكون تفريغ المواد داخل المخازن الشركة (واصله داخل المخزن) مع العمل

13- بإمكان المجهزين المخولين الراغبين في الحضور اثناء عملية سحب وفتح العروض الحضور الى مقر الشركة بعد الساعة 12 ظهرا ليوم الغلق .

14- يجب ان يكون هناك عرض فني ليتم المطابقة .

15- على جميع شركات تنفيذ الاعمال مع شركتنا تخصيص مشرف سلامه من قبلكم لديه الخبرة بالعمل في القطاع النفطي (يجب ان يمتلك شهاده في السلامة بالمواقع النفطية)

16-يقدم المجهز تعهد بالالتزام بالشروط المطلوبة في المواصفات (9 فقرات (تجهيز المواد الكيماويه)) ومنها شهاده المنشأ و شهاده الفاحص الثالث...الخ عند التجهيز

ت	رقم الطلبية	المواد المطلوبة	تاريخ الغلق
1	2025/507	مواد مخزنيه	2025/8/26
		وحسب استمارة العروض المرفقة	

نسخة منه الى :-

قسم تقنية المعلومات لغرض النشر بالموقع الالكتروني...مع التقدير

شعبة الشراء المباشر / شعبة المتابعة...مع الاوليات

لجنة استلام العروض ... للعلم لطفا

مسؤول شعبة الشراء المباشر

مرتضى عبد السالم نعمه

حسين جاسم /مخزنيه

ترغب الشركة شراء المواد المدرجة ادناه راجين تثبيت الاسعار الفقرات المتوفرة و اعادة الطلب موقع من قبلكم قبل نهاية الدوام الرسم ليوم ملاحظة/ في حال تجاوز مبلغ الاحالة عن 50,000,000 دينار فقط خمسون مليون ،دينار يتوجب تنظيم عقد مع الشركة يتضمن تقديم المستمسكات المطلوبة وفق تعليمات تنفيذ العقود الحكومية رقم 2 لسنة 2014 يرفق مع العرض نسخة من هوية غرفة التجارة مع الهوية الضريبية نافذة

ت	الموصفات	الكمية المطلوبة	المنشأ المطلوب	فتره التجهيز	سعر المفرد بالدينار	الملاحظات
1	مواد مخزنيه				رقماً كتابة	
	وحسب المواصفات المرفقة				المبلغ الاجمالي رقما المبلغ الاجمالي كتابه	

- ملاحظة/ مدة نفاذية العرض لا تقل عن ثلاث (3) اشهر
- يمنع الحك و الشطب و التصحيح بالاستمارة
- يغلق و يختم الظرف من قبل المجهز

اسم المجهز :
توقيع المجهز :
التاريخ :
ختم المجهز :



يتبع لطفاً (2-1)

شروط التجهيز لطلبات الشراء المباشر

- 1- يلتزم مقدم العطاء الذي تحال عليه الطلبية بتجهيز الشركة بالمواد المحددة مواصفاتها و منشئها في استمارة طلب الاسعار المرفقة و الذي يعتبر جزء لا يتجزأ من هذه الطلبية كما و يلتزم بان تكون كافة المواد جديدة و غير مستعملة الا اذا ورد غير ذلك .
 - 2- تدون اسعار العطاء بالعدد رقماً و كتابة و يكون السعر لوحده لكل فقرة كما هو مدون في استمارة طلب الاسعار دون تغيير او تعديل و يجب ان تكون الشروط و استمارة الاسعار المختومة بختم شركة مصافي الجنوب و موقعة من قبل مقدم العطاء و ختم المحل او الشركة عليه .
 - 3- لا يجوز الحك او الشطب في استمارة طلب الاسعار و كل تصحيح في الاسعار او غيره يجب اعادة كتابته رقماً و كتابةً و التوقيع اذاه .
 - 4- يلتزم مقدم العطاء الذي تحال عليه الطلبية بتجهيز كافة المواد المطلوبة خلال () يوم تبداً من تاريخ التبليغ بالإحالة و بعكسه فانه يتحمل غرامة تأخيريه يتم احتسابها لاحقاً حسب المعادلة (مبلغ الطلبية/مدة العقد * 10%) على ان لا يتجاوز مجموع الغرامات التأخيرية عن 10% من قيمة الطلبية و في حالة التجاوز يحق للشركة تنفيذ الطلبية على حساب المجهز،
 - 5- تستلم المواد بعد فحصها من قبل لجنة فنية مختصة في الشركات تؤيد صلاحيتها للعمل و اذا ظهر عدم صلاحيتها او عدم مطابقتها للمواصفات المطلوبة المواصفات المطلوبة و خلال فترة اسبوع من تاريخ التبليغ بعدم المطابقة و بعكسه يتم تحميله الغرامات التأخيرية يلتزم المجهز بتبديل هذه المادة و بنفس المنصوص عليها في الفقرة (4) اعلاه .
 - 7- يتم صرف مستحقات المجهز بعد تسلم كافة المواد وفق المواصفات و الشروط المطلوبة و اصدار استمارة المطابقة و مستندات الاستلام النهائية .
 - 8- الشركة غير ملزمة بقبول اوطأ العطاءات و الطلبية قابلة للتجزئة حسب اوطأ الاسعار .
 - 9- يلتزم مقدم العطاء بتثبيت عنوانه ورقم هاتفه و إيميل فعال و التوقيع على كافة الشروط و جداول للطلبية .
 - 10- يحق للشركة اهمال اي عطاء لا تتوفر فيه الشروط المطلوبة كما يحق لها الغاء الطلبية .
 - 11- يقدم المجهز تعهد بالالتزام بالشروط المطلوبة في المواصفات (9 فقرات (تجهيز المواد الكيماوية)) ومنها شهادته المنشأ و شهادته الفاحص الثالث... الخ عند التجهيز
- اطلعت على الشروط اعلاه



- الاسم الكامل :
- العنوان الكامل :
- رقم الهاتف الفعال :
- لتوقيع:
- E mail :

الكمية		وحدة الصرف	اسم المادة والمواصفات																
1-	742753025.3	NOS	SPARE PARTS FOR GOULD PUMP <table><tr><th>ITEM NO.</th><th>MODEL</th><th>SIZE</th><th>DRAWING NO.</th></tr><tr><td>P02 A, BT</td><td>3620</td><td>10×12-19XSQ</td><td>C2-261948 ,C2-261949</td></tr></table> SEAL COOLER SPARE PARTS FOR GOULD PUMP <table><tr><th>.ITEM NO</th><th>MODEL</th><th>SIZE</th><th>.DRAWING NO</th></tr><tr><td>P09 A, B,CT</td><td>3620</td><td>4×8-13A</td><td>C2-261957 ,C2-261959</td></tr></table> SEAL COOLER	ITEM NO.	MODEL	SIZE	DRAWING NO.	P02 A, BT	3620	10×12-19XSQ	C2-261948 ,C2-261949	.ITEM NO	MODEL	SIZE	.DRAWING NO	P09 A, B,CT	3620	4×8-13A	C2-261957 ,C2-261959
ITEM NO.	MODEL	SIZE	DRAWING NO.																
P02 A, BT	3620	10×12-19XSQ	C2-261948 ,C2-261949																
.ITEM NO	MODEL	SIZE	.DRAWING NO																
P09 A, B,CT	3620	4×8-13A	C2-261957 ,C2-261959																
2-	742760026.3	NOS	ملاحظة // - المنشأ (امريكي ، اوريبي) - تخويل الشركة الممثلة - توفير شهادة منشأ عند التجهيز - فترة التجهيز (6) اشهر - الشركات المطلوبة (John Crane – Flowsewe – AES SEAL – Eagle Burgmann) • علماً أن نوع المبادلة SEAL COOLER هو SHELL AND TUBE والمعدن الخاص ب: tube هو STAINLESS (STEEL)																

خذه منه الى/

- قسم المعدات الدوارة / تعزيز دوري حسب مذكرتكم المرقمة 1840 في 2025/7/14 - للعلم ... مع التقدير
- قسم المخازن - شعبة حركة المواد - مع التقدير
- قسم المخازن - شعبة السيطرة المخزنية مع الاوليات

مصادقة السيد المدير العام


REVISION(1-1)12/4/2021

HAIDER KAREEN




1712

٢١/٤

PUMP									
Service: Atmospheric Residue Pump					Item N°: P09 A,B,CT				
1	Type	centrifugal, Model:3620 S Size:4x8-13A			Manufactured by GOULDS PUMPS				
2	Number Required Operating	2			Number Required Spare 1				
3	Driver / Main	A - electric motor, B - electric motor			Driver / Spare CT - steam turbine				
4	LIQUID		OPERATING CONDITIONS			SITE CONDITION			
5	Operation	continuous			Capacity Operating	147 m ³ /h		Ambient Temps. Min./Max. -8/55 °C	
6	Liquid	Atm. Residue			Capacity Design	169 m ³ /h		Relative Humidity Min./Max. 12/90 %	
7	Pumping Temperature	350 °C			Discharge Pressure	13.1 kg/cm ² g		Altitude (above sea level) 30 m	
8	Density (at P. T.)	785 kg/m ³			Suct. Press. Oper./Max.	2.1/ kg/cm ² g		Location	
9	Vapour Press. (at P. T.)	2.98 kg/cm ² a			Diff. Press. (at oper. cap.)	11 kg/cm ²		☐ Indoor ☐ Heated ☐ Under Roof ☒ Outdoor ☐ Unheated ☐ Sun	
10	Viscosity (at P. T.)	0.86 cP			Diff. Head (at oper. cap.)	140 m (liq.)			
11	Corr./Eros. due to				NPSH (available)	2.5 m (liq.)		Area Classification	
12	PERFORMANCE								
13	Proposal Curve N°				NPSH (required)	2.04 m (liq.)		N° of Stages	
14	Speed	2975 RPM			Min. Continuous Flow	81.8 m ³ /h		Suction Specific Speed	
15	Nom. Hydraulic Power	67.9 kW			Max. Head Rated Impeller	m		Noise Level (at 1m) <85 dBA	
16	Efficiency	64.5 %			Max. Power Rated Impeller	kW		Estimated Shutoff Press. 14.0 kg/cm ² g	
17	Impeller Diameter	Max. 330 mm			Rated 323 mm	Min. 255 mm		Type of Impeller enclosed	
18	MATERIALS AND CONSTRUCTION								
19	Applicable Standard	☒ API 610 10 th Edition ☐ Other			NOZZLES				
20	Casing Mounting					Size	Rating	Facing	Position
21	Casing Split	☐ Axial ☐ Radial			☒ Suction	8"	300#	RF	
22	Casing Min. Thick./Corr. Allowance	mm			☒ Discharge	4"	300#	RF	
23	Casing Type (impeller mounted)				☐ Bal. Drum				
24	Max. Allowable Work. Pressure	31.0 kg/cm ² g at 350 °C			PRESSURE CASING CONNECTIONS				
25	Hydro Test Pressure	kg/cm ² g			☐ Drain				
26	Rotation (viewed from CPLG)	☐ CW ☒ CCW			☐ Vent				
27	Coupling	TSCS 0075-S.F. 1.5/ 7.5 kW/100 RPM MFR Metastream			☐ Pressure Gauge				
28	Driver Half Coupling Mounted by	pump MFR			☐ Temp. Gauge				
29	Packing	Size/Rings N° MFR			☐ Warm-Up				
30	Mech. Seal Unpress. Dual	Class Code BTPRN MFR J. Crane			☐ Bal./Leak-Off				
31	Gland Taps	☐ Flush ☐ Drain ☐ Buffer			MATERIALS				
32		☐ Quench ☐ Cooling ☐ Other			Appendix H Class C-6 Min. Design Metal Temp. °C				
33	Bearing Type/N°	☐ Radial ☐ Thrust			Barrel/Case	12%Cr	Sleeve	316SS	
34					Impeller	12%Cr	Diffuser		
35	Lubrication	ring oil			Wear Rings	12%Cr	CPLG Spacer/Hubs		
36	Pressure Lube Sys.	☐ API610 ☐ API614			Shaft	17-4PH	CPLG Disks		
37	AUXILIARY PIPING								
38	Seal Flush Piping Plan	11/52			Auxiliary Flush Plan	Cooling Water Plan			
39	Piping Assembly	socket welded			Extern. Seal Flush Fluid	m ³ /h		Total Cooling Water m ³ /h	
40	TESTING				WEIGHT				
41	☐ Hydrostatic				☐ Sound Level Test	Pump kg			
42	☐ Performance				☐ Shop Inspection	Baseplate kg			
43	☐ NPSH				☐ Dismant.&Insp. Test	Motor kg			
44	☐ Complete Unit Test				☐ Material Inspection	Total kg			
45	EL. MOTOR DRIVEN PUMP				TURBINE DRIVEN PUMP				
46	Item N°	MTD by pump MFR			Item N°	MTD by purchaser			
47	Power	90 kW Synchr. Speed 2975 RPM			Power	101 kW Synchr. Speed 2975 RPM			
48	MFR	Earthing System			MFR	Dresser Rand			
49	Type	KD1315S-AA41F Insulation/SF F/1.00			Inlet Steam	27/30/33 (min./norm./max.) kg/cm ² g Temp. 380/400/410 °C			
50	Volt./ Ph./Hz	380 / 3 / 50			Exhaust Steam	4/5/6.5 (min./norm./max.) kg/cm ² g Temp. °C			
51	Ex-Proof	EEEx de IIB T4 Normal Prot.			Steam Rate	kg/h			
52									
53	Notes: Design Case - Mishrif Crude Oil								
54									
55									
56									
4	KUN	SKR	PKP	02/2010	for Construction	Project New Crude Distillation Unit, Basrah, Iraq			
3	SKR	VOD	PKP	12/2008	for Construction	Customer South Refineries Co.			
2	SKR	VOD	PKP	06/2008	for Construction	Order N°			
1	SKR	VOD	PKP	02/2008	for Construction				
0	SKR	VOD	PKP	09/2007	for Proposal				
R.	Des.	Chd.	Ap.	Date	Description				
Property of P.E. can be used only in reference to contract or proposals of this company. Reproduction of this print disclosed is prohibited.						Page 1/1			



PUMP											
Service: Desalted Crude Oil Pump					Item N°: P02 A,BT						
1	Type	centrifugal, Model:3620 L Size:10x12-19XSQ			Manufactured by GOULDS PUMPS						
2	Number Required Operating	1			Number Required Spare 1						
3	Driver / Main	electric motor			Driver / Spare steam turbine						
4	LIQUID		OPERATING CONDITIONS			SITE CONDITION					
5	Operation	continuous			Capacity Operating	511 m ³ /h		Ambient Temps. Min./Max. -8/55 °C			
6	Liquid	Desalted Crude Oil			Capacity Design	537 m ³ /h		Relative Humidity Min./Max. 12/90 %			
7	Pumping Temperature	122 °C			Discharge Pressure	30.7 kg/cm ² g		Altitude (above sea level) 30 m			
8	Density (at P. T.)	807 kg/m ³			Suct. Press. Oper./Max.	10.4/ kg/cm ² g		Location			
9	Vapour Press. (at P. T.)	7.15 kg/cm ² a			Diff. Press. (at oper. cap.)	20.3 kg/cm ² g		☐ Indoor ☐ Heated ☐ Under Roof ☒ Outdoor ☐ Unheated ☐ Sun			
10	Viscosity (at P. T.)	1.75 cP			Diff. Head (at oper. cap.)	252 m (liq.)					
11	Corr./Eros. due to				NPSH (available)	40 m (liq.)		Area Classification			
12	PERFORMANCE										
13	Proposal Curve N°				NPSH (required)	5.05 m (liq.)		N° of Stages 1			
14	Speed	2980 RPM			Min. Continuous Flow	238 m ³ /h		Suction Specific Speed			
15	Nom. Hydraulic Power	416 kW			Max. Head Rated Impeller	m		Noise Level (at 1m) <85 dBA			
16	Efficiency	68 %			Max. Power Rated Impeller	kW		Estimated Shutoff Press. 32.4 kg/cm ² g			
17	Impeller Diameter	Max. 475 mm			Rated 446 mm	Min. 406 mm		Type of Impeller enclosed			
18	MATERIALS AND CONSTRUCTION										
19	Applicable Standard	☒ API 610 10 th Edition ☐ Other			NOZZLES						
20	Casing Mounting					Size	Rating	Facing	Position		
21	Casing Split	☐ Axial ☐ Radial			☒ Suction	12"	300#	RF			
22	Casing Min. Thick./Corr. Allowance	mm			☒ Discharge	10"	300#	RF			
23	Casing Type (impeller mounted)				☐ Bal. Drum						
24	Max. Allowable Work. Pressure	41.2 kg/cm ² g at 122 °C			PRESSURE CASING CONNECTIONS						
25	Hydro Test Pressure	kg/cm ² g			☐ Drain						
26	Rotation (viewed from CPLG)	☐ CW ☒ CCW			☐ Vent						
27	Coupling	TSCS 0350-S.F. 1.50 35 kW/100 RPM MFR Metastream			☐ Pressure Gauge						
28	Driver Half Coupling Mounted by	pump MFR			☐ Temp. Gauge						
29	Packing	Size/Rings N° MFR			☐ Warm-Up						
30	Mech. Seal	Unpress. Dual Class Code BTPFN MFR J. Crane			☐ Bal./Leak-Off						
31	Gland Taps	☐ Flush ☐ Drain ☐ Buffer			MATERIALS						
32		☐ Quench ☐ Cooling ☐ Other			Appendix H Class C-6 Min. Design Metal Temp. °C						
33	Bearing Type/N°	☐ Radial			Barrel/Case	12%Cr		Sleeve	316SS		
34		☐ Thrust			Impeller	12%Cr		Diffuser			
35	Lubrication	ring oil			Wear Rings	12%Cr		CPLG Spacer/Hubs			
36	Pressure Lube Sys.	☐ API610 ☐ API614			Shaft	17-4PH		CPLG Disks			
37	AUXILIARY PIPING										
38	Seal Flush Piping Plan	23/52			Auxiliary Flush Plan	Cooling Water Plan					
39	Piping Assembly	socket welded			Extern. Seal Flush Fluid	m ³ /h		Total Cooling Water	m ³ /h		
40	TESTING				WEIGHT						
41	☐ Hydrostatic				☐ Sound Level Test	Pump		kg			
42	☐ Performance				☐ Shop Inspection	Baseplate		kg			
43	☐ NPSH				☐ Dismant.&Insp. Test	Motor		kg			
44	☐ Complete Unit Test				☐ Material Inspection	Total		kg			
45	EL. MOTOR DRIVEN PUMP				TURBINE DRIVEN PUMP						
46	Item N°	MTD by pump MFR			Item N°	MTD by purchaser					
47	Power	470 kW Synchr. Speed 2980 RPM			Power	503 kW Synchr. Speed 2980 RPM					
48	MFR	SCHORCH Earthing System			MFR	Dresser Rand					
49	Type	KD2450X-AH41B Insulation/SF F/1.00			Inlet Steam	27/30/33 (min./norm./max.) kg/cm ² g Temp. 380/400/410 °C					
50	Volt./ Ph./Hz	3300 / 3 / 50			Exhaust Steam	4/5/6.5 (min./norm./max.) kg/cm ² g Temp.					
51	Ex-Proof	EEx de IIB T4 Normal Prot. IP55			Steam Rate	kg/h					
52											
53	Notes: Design Case - Mishrif Crude Oil										
54											
55											
56											
					Project New Crude Distillation Unit, Basrah, Iraq						
					Customer South Refineries Co.						
					Order N°						
2	SKR	VOD	PKP	12/2008	for Construction						Page
1	SKR	VOD	PKP	02/2008	for Construction						1/1
0	SKR	VOD	PKP	09/2007	for Proposal						
R.	Des.	Chd.	Ap.	Date	Description						