

مرفق رقم (1) شركة مصافي الجنوب (شركة عامة)

العدد: 596
التاريخ: 2025/10/16

هياة المواد
شعبة الشراء المباشر

م/ اعاده اعلان طلبية شراء (2025/513)

تعلن شركة مصافي الجنوب (شركة عامة) طلبيات شراء كما في ادناه فعلى الراغبين بالتجهيز التقديم على الطلبات المعلنة سحب استمارة العروض وكذلك الشروط والمواصفات واي مرفقات اخرى وأملانها (سعر المفرد والمجموع رقما وكتابة مع تثبيت التاريخ وكذلك التوقيع والختم الحي على استمارة العروض وكذلك الشروط والمواصفات وكافة المرفقات) ويرفق مع العرض المستمسكات البيانات ادناه:

- 1- نسخة حديثة مصورة من هوية غرفة التجارة بالنسبة للمكاتب.
- 2- نسخة مصورة من هوية تصنيف بالنسبة لشركات المقاولات
- 3- نسخة مصورة من هوية الأحوال المدنية أو البطاقة الوطنية للمدير المفوض
- 4- نسخة مصورة من بطاقة السكن 5- شهادة تأسيس الشركة
- 6- تزويدنا بعنوان كامل ودقيق للمجهز او الشركة واقرب نقطه داله ورقم الهاتف ويلتزم مقدم العطاء بتثبيت عنوانه و إيميل فعال كتابه في ورقه مستقلة طباعه ومختوم وتقدم تأييد سكن مصدق من المجلس البلدي حديث يتضمن مكان الشركة او المكتب مع رقم الحساب المصرفي IBAN
- 7- تقديم هوية ضريبية نافذة المفعول عند تقديم العروض وكذلك عند صرف المستحقات
- يتم وضع العروض والمستمسكات والبيانات أعلاه في مغلف ويعنون الى شركة مصافي الجنوب (مع تزويدنا جميع المعلومات على قرص يرفق مع العروض الورقية) / هينه المواد/شعبه الشراء المباشر ويثبت عليه المعلومات التالية :-
- أ- رقم الطلبية وتاريخها ب- موضوع الطلبية ج- تاريخ الغلق د- أسم الشركة المقدمة مع الختم على طرفي المغلف .
- و- مراجعة مقر الشركة الكائن في الشعبة / استعلامات الشركة الخارجية لغرض تسليم العروض في الصناديق المخصصة علما اخر موعد لتسليم العروض قبل الساعة الثانية عشر ظهرا من يوم الغلق .
- 8- في حال قيام الشركات او المكاتب باي عملية فساد او احتيال او تواطى سوف تلغى الاستمارة المقدمة ويتم إيقاف التعامل مع تلك المكاتب او الشركات ويتم اتخاذ كافة الاجراءات القانونية بحقهم
- 9- في حالة مصادفة يوم الغلق عطلة رسمية وعدم وجود دوام لأي سبب كان يؤجل موعد الغلق الى اليوم الذي يليه .
- 10- يكون تواجد لجنة استلام العروض ايام (الاحد – والثلاثاء – والخميس) من كل اسبوع
- 11- اعتبار تاريخ التبليغ عن طريق الايميل بداية فتره التجهيز على الإحالة
- 12- يكون تفرغ المواد داخل المخازن الشركة (واصله داخل المخزن) مع العمال
- 13- بإمكان المجهزين المخولين الراغبين في الحضور أثناء عملية سحب وفتح العروض الحضور الى مقر الشركة بعد الساعة 12 ظهرا ليوم الغلق .
- 14- يجب ان يكون هناك عرض فني ليتم المطابقة .
- 15- على جميع شركات تنفيذ الاعمال مع شركتنا تخصيص مشرف سلامه من قبلكم لديه الخبرة بالعمل في القطاع النفطي (يجب ان يمتلك شهاده في السلامة بالمواقع النفطية)
- 16- يقدم المجهز تعهد بالالتزام بالشروط المطلوبة في المواصفات المرفقه (9 فقرات (تجهيز المواد الكيماوية)) ومنها شهاده المنشأ و شهاده الفاحص الثالث ...الخ عند التجهيز

ت	رقم الطلبية	المواد المطلوبة	تاريخ الغلق
1	2025/513	مواد مخزنيه	2025/10/26
		وحسب استمارة العروض المرفقة	

نسخة منه الى:-

قسم تقنية المعلومات لغرض

+ النشر بالموقع الالكتروني ...مع التقدير

شعبة الشراء المباشر/ شعبة المتابعة...مع الاوليات

لجنة استلام العروض ... للعلم لطفا



ممسؤل شعبه الشراء المباشر

مرتضى عبد السالم نعمه

حيدر عبد الحضر عبد الصادر

حسين جاسم /مخزنيه



ترغب الشركة شراء المواد المدرجة ادناه راجين تثبيت الاسعار الفقرات المتوفرة و اعادة الطلب موقع من قبلكم قبل نهاية الدوام الرسم ليوم ملاحظة/ في حال تجاوز مبلغ الاحالة عن 50,000,000 دينار فقط خمسون مليون ،دينار يتوجب تنظيم عقد مع الشركة يتضمن تقديم المستمسكات المطلوبة وفق تعليمات تنفيذ العقود الحكومية رقم 2 لسنة 2014 يرفق مع العرض نسخة من هوية غرفة التجارة مع الهوية الضريبية نافذة

ت	الموصفات	الكمية المطلوبة	المنشأ المطلوب	فتره التجهيز	سعر المفرد بالدينار	الملاحظات
1	مواد مخزنيه				رقماً	كتابة
	وحسب المواصفات المرفقة				المبلغ الاجمالي رقما	
					المبلغ الاجمالي كتابه	

- ملاحظة/ مدة نفاذية العرض لا تقل عن ثلاث (3) اشهر
- يمنع الحك و الشطب و التصحيح بالاستمارة
- يغلق و يختم الطرف من قبل المجهز

اسم المجهز :
توقيع المجهز :
التاريخ :
ختم المجهز :



يتبع لطفا (2-1)

شروط التجهيز لطلبات الشراء المباشر

- 1- يلتزم مقدم العطاء الذي تحال عليه الطلبية بتجهيز الشركة بالمواد المحددة مواصفاتها و منشئها في استمارة طلب الاسعار المرفقة و الذي يعتبر جزء لا يتجزأ من هذه الطلبية كما و يلتزم بان تكون كافة المواد جديدة و غير مستعملة الا اذا ورد غير ذلك .
 - 2- تدون اسعار العطاء بالعدد رقماً و كتابة و يكون السعر لوحده لكل فقرة كما هو مدون في استمارة طلب الاسعار دون تغيير او تعديل و يجب ان تكون الشروط و استمارة الاسعار المختومة بختم شركة مصافي الجنوب و موقعة من قبل مقدم العطاء و ختم المحل او الشركة عليه .
 - 3- لا يجوز الحك او الشطب في استمارة طلب الاسعار و كل تصحيح في الاسعار او غيره يجب اعادة كتابته رقماً و كتابةً و التوقيع اذاه .
 - 4- يلتزم مقدم العطاء الذي تحال عليه الطلبية بتجهيز كافة المواد المطلوبة خلال () يوم تبداً من تاريخ التبليغ بالإحالة و بعكسه فانه يتحمل غرامة تأخيره يتم احتسابها لاحقاً حسب المعادلة (مبلغ الطلبية/مدة العقد * 10%) على ان لا يتجاوز مجموع الغرامات التأخيرية عن 10% من قيمة الطلبية و في حالة التجاوز يحق للشركة تنفيذ الطلبية على حساب المجهز.
 - 5- تستلم المواد بعد فحصها من قبل لجنة فنية مختصة في الشركات تؤيد صلاحيتها للعمل و اذا ظهر عدم صلاحيتها او عدم مطابقتها للمواصفات المطلوبة المواصفات المطلوبة و خلال فترة اسبوع من تاريخ التبليغ بعدم المطابقة و بعكسه يتم تحميله الغرامات التأخيرية يلتزم المجهز بتبديل هذه المادة و بنفس المنصوص عليها في الفقرة (4) اعلاه .
 - 7- يتم صرف مستحقات المجهز بعد تسلم كافة المواد وفق المواصفات و الشروط المطلوبة و اص دار استمارة المطابقة و مستندات الاستلام النهائية .
 - 8- الشركة غير ملزمة بقبول اوطأ العطاءات و الطلبية قابلة للتجزئة حسب اوطأ الاسعار .
 - 9- يلتزم مقدم العطاء بتثبيت عنوانه ورقم هاتفه و إيميل فعال و التوقيع على كافة الشروط و جداول للطلبية .
 - 10- يحق للشركة اهمال اي عطاء لا تتوفر فيه الشروط المطلوبة كما يحق لها الغاء الطلبية .
 - 11-16- يقدم المجهز تعهد بالالتزام بالشروط المطلوبة في المواصفات (9 فقرات (تجهيز المواد الكيماوية)) ومنها شهادته المنشأ و شهادته الفاحص الثالث الخ عند التجهيز
- اطلعت على الشروط اعلاه



- الاسم الكامل :
- العنوان الكامل :
- رقم الهاتف الفعال :
- لتوقيع:
- E mail :

الكمية	وحدة الصرف	اسم المادة والمواصفات	الرقم الرمزي	ت																
1	NOS	SPARE PARTS FOR GOULD PUMP <table><tr><th>ITEM NO.</th><th>MODEL</th><th>SIZE</th><th>DRAWING NO.</th></tr><tr><td>P06 A, B</td><td>3700</td><td>2x4-9A</td><td>B261954C</td></tr></table> SEAL COOLER SPARE PARTS FOR GOULD PUMP <table><tr><th>.ITEM NO</th><th>MODEL</th><th>SIZE</th><th>.DRAWING NO</th></tr><tr><td>P07 A, B</td><td>3700</td><td>3x6-11S</td><td>A261955C</td></tr></table> SEAL COOLER	ITEM NO.	MODEL	SIZE	DRAWING NO.	P06 A, B	3700	2x4-9A	B261954C	.ITEM NO	MODEL	SIZE	.DRAWING NO	P07 A, B	3700	3x6-11S	A261955C	742757026.3	1-
		ITEM NO.	MODEL	SIZE	DRAWING NO.															
P06 A, B	3700	2x4-9A	B261954C																	
.ITEM NO	MODEL	SIZE	.DRAWING NO																	
P07 A, B	3700	3x6-11S	A261955C																	
1	NOS	ملاحظة // - المنشأ (امريكي ، اوريبي) - تخويل الشركة المصنعة - توفير شهادة منشأ - فترة التجهيز (6) اشهر - الشركات المطلوبة (John Crane - Flowsewe - AES SEAL - Eagle Burgmann) • علماً ان نوع المبادلة هو SEAL COOLER هو SH AND TUBE والمعدن الخاص ب: tube هو STAINLESS (STEEL)	742758025.3	2-																

نسخه منه الى/

- قسم المعدات الدوارة / تعزيز دوري حسب مذكرتكم المرقمة 1841 في 2025/7/14 - للعلم ... مع التقدير
- قسم المخازن - شعبة حركة المواد - مع التقدير
- قسم المخازن - شعبة السيطرة المخزنية مع الاولويات


مصادقة السيد المدير العام

REVISION(1-1)12/4/2021



HAIDER KAREEM

١٦٢٤
٧١٢٩

PUMP										
Service: Kerosene Pump					Item N° P06 A,B					
1	Type	centrifugal, Model: 3700 SX Size: 2x4-9A			Manufactured by GOULDS PUMPS					
2	Number Required Operating	1			Number Required Spare 1					
3	Driver / Main	electric motor			Driver / Spare electric motor					
4	LIQUID		OPERATING CONDITIONS			SITE CONDITION				
5	Operation	continuous			Capacity Operating	60 m ³ /h		Ambient Temps. Min./Max. -8/55 °C		
6	Liquid	Kerosene			Capacity Design	69 m ³ /h		Relative Humidity Min./Max. 12/90 %		
7	Pumping Temperature	191 °C			Discharge Pressure	6.09 kg/cm ² g		Altitude (above sea level) 30 m		
8	Density (at P. T.)	659 kg/m ³			Suct. Press. Oper./Max.	2.6/ kg/cm ² g		Location		
9	Vapour Press. (at P. T.)	2.42 kg/cm ² a			Diff. Press. (at oper. cap.)	3.49 kg/cm ²		☐ Indoor ☐ Heated ☐ Under Roof		
10	Viscosity (at P. T.)	0.23 cP			Diff. Head (at oper. cap.)	53 m (liq.)		☒ Outdoor ☐ Unheated ☐ Sun		
11	Corr./Eros. due to	NPSH (available)			16 m (liq.)		Area Classification			
12	PERFORMANCE									
13	Proposal Curve N°	NPSH (required)			1.95 m (liq.)		N° of Stages 1			
14	Speed	2950 RPM			Min. Continuous Flow	20.4 m ³ /h		Suction Specific Speed		
15	Nom. Hydraulic Power	8.72 kW			Max. Head Rated Impeller	m		Noise Level (at 1m) <85 dBA		
16	Efficiency	65.5 %			Max. Power Rated Impeller	kW		Estimated Shutoff Press. 6.5 kg/cm² g		
17	Impeller Diameter	Max. 235 mm		Rated 209 mm	Min. 152 mm		Type of Impeller enclosed			
18	MATERIALS AND CONSTRUCTION									
19	Applicable Standard	☒ API 610 10 th Edition ☐ Other			NOZZLES					
20	Casing Mounting					Size	Rating	Facing	Position	
21	Casing Split	☐ Axial ☐ Radial			☒ Suction	4"	300#	RF	end	
22	Casing Min. Thick./Corr. Allowance	mm			☒ Discharge	2"	300#	RF	top	
23	Casing Type (impeller mounted)				☐ Bal. Drum					
24	Max. Allowable Work. Pressure	36.9 kg/cm ² g at 191 °C			PRESSURE CASING CONNECTIONS					
25	Hydro Test Pressure	kg/cm ² g			☒ Drain	3/4"				
26	Rotation (viewed from CPLG)	☐ CW ☒ CCW			☐ Vent					
27	Coupling	TSCS 0013-S.F. 1.50 1.3 kW/100 RPM MFR Metastream			☐ Pressure Gauge					
28	Driver Half Coupling Mounted by	pump MFR			☐ Temp. Gauge					
29	Packing	Size/Rings N° MFR			☐ Warm-Up					
30	Mech. Seal	single Class Code BSARN MFR J. Crane			☐ Bal./Leak-Off					
31	Gland Taps	☐ Flush ☐ Drain ☐ Buffer			MATERIALS					
32		☐ Quench ☐ Cooling ☐ Other			Appendix H Class C-6 Min. Design Metal Temp. °C					
33	Bearing Type/N°	☐ Radial			Barrel/Case	12%Cr		Sleeve	316SS	
34		☐ Thrust			Impeller	12%Cr		Diffuser		
35	Lubrication	ring oil			Wear Rings	12%Cr		CPLG Spacer/Hubs		
36	Pressure Lube Sys.	☐ API610 ☐ API614			Shaft	410SS		CPLG Disks		
37	AUXILIARY PIPING									
38	Seal Flush Piping Plan	21/62			Auxiliary Flush Plan	Cooling Water Plan				
39	Piping Assembly	socket welded			Extern. Seal Flush Fluid	m ³ /h		Total Cooling Water	m ³ /h	
40	TESTING				WEIGHT					
41	☐ Hydrostatic	☐ Sound Level Test			Pump	200 kg				
42	☐ Performance	☐ Shop Inspection			Baseplate	kg				
43	☐ NPSH	☐ Dismant.&Insp. Test			Motor	107 kg				
44	☐ Complete Unit Test	☐ Material Inspection			Total	kg				
45	EL. MOTOR DRIVEN PUMP				TURBINE DRIVEN PUMP					
46	Item N°	MTD by pump MFR			Item N°	MTD by				
47	Power	11 kW Synchr. Speed 2950 RPM			Power	kW		Synchr. Speed	RPM	
48	MFR	SCHORCH Earthing System			MFR					
49	Type	KD1160M-AA41F Insulation/SF F/1.00			Inlet Steam	kg/cm ² g		Temp.	°C	
50	Volt./ Ph./Hz	380 / 3 / 50			Exhaust Steam	kg/cm ² g		Temp.	°C	
51	Ex-Proof	EEx de IIB T4 Normal Prot. IP55			Steam Rate	kg/h				
52										
53	Notes: Design Case - Basrah Crude Oil									
54										
55										
56										
					Project New Crude Distillation Unit, Basrah, Iraq					
					Customer South Refineries Co.					
					Order N°					
1	SKR	VOD	PKP	12/2008	for Construction					Page.
0	SKR	VOD	PKP	02/2008	for Construction					
R.	Des.	Chd.	Ap.	Date	Description					

Property of P.E. can be used only in reference to contract or proposals of this company. Reproduction of this print disclosed is prohibited.



PUMP											
Service: LGO Pump					Item N°: P07 A,B						
1	Type	centrifugal, Model:3700 MX Size:3x6-11S			Manufactured by GOULDS PUMPS						
2	Number Required Operating	1			Number Required Spare 1						
3	Driver / Main	electric motor			Driver / Spare electric motor						
4	LIQUID		OPERATING CONDITIONS			SITE CONDITION					
5	Operation	continuous			Capacity Operating	107 m ³ /h		Ambient Temps. Min./Max. -8/55 °C			
6	Liquid	Light Gas Oil			Capacity Design	123 m ³ /h		Relative Humidity Min./Max. 12/90 %			
7	Pumping Temperature	252 °C			Discharge Pressure	7.09 kg/cm ² g		Altitude (above sea level) 30 m			
8	Density (at P. T.)	658 kg/m ³			Suct. Press. Oper./Max.	2.15/ kg/cm ² g		Location			
9	Vapour Press. (at P. T.)	2.52 kg/cm ² a			Diff. Press. (at oper. cap.)	4.94 kg/cm ²		☐ Indoor ☐ Heated ☐ Under Roof			
10	Viscosity (at P. T.)	0.22 cP			Diff. Head (at oper. cap.)	75 m (liq.)		☒ Outdoor ☐ Unheated ☐ Sun			
11	Corr./Eros. due to				NPSH (available)	9 m (liq.)		Area Classification			
12	PERFORMANCE										
13	Proposal Curve N°				NPSH (required)	3.47 m (liq.)		N° of Stages 1			
14	Speed	2965 RPM			Min. Continuous Flow	38.5 m ³ /h		Suction Specific Speed			
15	Nom. Hydraulic Power	20.7 kW			Max. Head Rated Impeller	m		Noise Level (at 1m) <85 dBA			
16	Efficiency	69.5 %			Max. Power Rated Impeller	kW		Estimated Shutoff Press. 8.0 kg/cm ² g			
17	Impeller Diameter	Max. 283 mm		Rated 246 mm	Min. 203 mm	Type of Impeller enclosed					
18	MATERIALS AND CONSTRUCTION										
19	Applicable Standard	☒ API 610 10 th Edition ☐ Other			NOZZLES						
20	Casing Mounting				☒ Suction	Size	Rating	Facing	Position		
21	Casing Split	☐ Axial ☐ Radial			☒ Discharge	6"	300#	RF	end		
22	Casing Min. Thick./Corr. Allowance	mm			☐ Bal. Drum	3"	300#	RF	top		
23	Casing Type (impeller mounted)				PRESSURE CASING CONNECTIONS						
24	Max. Allowable Work. Pressure	34.1 kg/cm ² g at 252 °C			☒ Drain	3/4"					
25	Hydro Test Pressure	kg/cm ² g			☐ Vent						
26	Rotation (viewed from CPLG)	☐ CW ☒ CCW			☐ Pressure Gauge						
27	Coupling	TSCS 0033-S.F. 1.50 3.3 kW/100 RPM MFR Metastream			☐ Temp. Gauge						
28	Driver Half Coupling Mounted by	pump MFR			☐ Warm-Up						
29	Packing	Size/Rings N° MFR			☐ Bal./Leak-Off						
30	Mech. Seal	single Class Code BSARN MFR J. Crane			MATERIALS						
31	Gland Taps	☐ Flush ☐ Drain ☐ Buffer			Appendix H Class C-6 Min. Design Metal Temp. °C						
32		☐ Quench ☐ Cooling ☐ Other			Barrel/Case	12%Cr	Sleeve	316SS			
33	Bearing Type/N°	☐ Radial			Impeller	12%Cr	Diffuser				
34		☐ Thrust			Wear Rings	12%Cr	CPLG Spacer/Hubs				
35	Lubrication	ring oil			Shaft	410SS	CPLG Disks				
36	Pressure Lube Sys.	☐ API610 ☐ API614									
37	AUXILIARY PIPING										
38	Seal Flush Piping Plan	21/62		Auxiliary Flush Plan	Cooling Water Plan						
39	Piping Assembly	socket welded		Extern. Seal Flush Fluid	m ³ /h		Total Cooling Water m ³ /h				
40	TESTING				WEIGHT						
41	☐ Hydrostatic				☐ Sound Level Test		Pump 300 kg				
42	☐ Performance				☐ Shop Inspection		Baseplate 393 kg				
43	☐ NPSH				☐ Dismant.&Insp. Test		Motor 263 kg				
44	☐ Complete Unit Test				☐ Material Inspection		Total 956 kg				
45	EL. MOTOR DRIVEN PUMP				TURBINE DRIVEN PUMP						
46	Item N°	MTD by pump MFR			Item N°	MTD by					
47	Power	30 kW		Synchr. Speed 2965 RPM	Power	kW		Synchr. Speed	RPM		
48	MFR	SCHORCH		Earthing System	MFR						
49	Type	KD1200L-AA41F Insulation/SF F/1.00			Inlet Steam	kg/cm ² g		Temp.	°C		
50	Volt./ Ph./Hz	380 / 3 / 50			Exhaust Steam	kg/cm ² g		Temp.	°C		
51	Ex-Proof	EEx de IIB T4		Normal Prot. IP55	Steam Rate	kg/h					
52											
53	Notes: Design Case - Basrah Crude Oil										
54											
55											
56											
					Project New Crude Distillation Unit, Basrah, Iraq						
					Customer South Refineries Co.						
					Order N°						
1	SKR	VOD	PKP	12/2008	for Construction						Page 1/1
0	SKR	VOD	PKP	02/2008	for Construction						
R.	Des.	Chd.	Ap.	Date	Description						

Property of P.E. can be used only in reference to contract or proposals of this company. Reproduction of this print is prohibited.

